



Woodstock Power Company
 4055 Richmond Street
 Philadelphia, PA 19137
 P: 610-658-3242

Job Name: XXXX
 Version 1.0
 6/15/2022

Qty:	Description	
1	KG125 Generator Set	GMKG125 KG125-CP1
	Literature Languages	English
	Approvals and Listings	UL2200 Listing
	Engine	SnglFuel,UL,PreAlarm,NG,StdbY
	Nameplate Rating	Standby 130C Rise
	Voltage	60Hz, 120/208V, Wye, 3Ph, 4W
	Alternator	4R13X
	Cooling System	Unit Mounted Radiator, 50C
	Skid and Mounting	Skid, 44"
	Air Intake	Standard Duty
	Controller	APM402
	Enclosure Type	Sound
	Enclosure Material	Steel
	Starting Aids, Installed	1500W,110-120V
	Electrical Accy.,Installed	Battery, 1/12V, Wet
	Electrical Accy.,Installed	Battery Charger, 6A
	Electrical Accy.,Installed	Run Relay
	Electrical Accy.,Installed	2 Input/5 OutputModule
	Rating, LCB 1	80% Rated
	Amps, LCB 1	600
	Trip Type, LCB 1	Electronic, LSI
	Interrupt Rating LCB 1	35kA at 480V
	Exceeds LTL Shipping Height	Add'l Shipping Charge Accepted
	Miscellaneous Accy,Installed	Coolant in Genset
	Warranty	5 Year Comprehensive
	Testing, Additional	Power Factor Test,0.8,3Ph Only
4	Lit Kit, General Maint, KG125	Part No: GM13706-KP2
4	Flexible Fuel Line (Nat/LP)	Part No: PA-343303
4	Gaseous Fuel Filter	Part No: GM105786-KP