



Load Bank Test Report

Customer WPC

Date: 7/19/2023

1. Autostart Function LOP HWT OS Hz
 2. Battery Voltage (running)

Job # / Location SHOP
 Brand **MULTIQ**
 Model **DCA-220SSJU**
 Serial **8010592**
 Engine
 KW **160KW**
 Voltage **277/480V**

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Temp. F	Temp. F	kW	Hours
12:15	484.1	484.2	484.1	63.1	63.2	63.3	60	77	185	86	52.9	
12:30	483.4	483.6	483.4	120.6	120.5	120.6	60	77	185	87	100.6	
12:45	483	483	483	200.8	200.7	200.9	60	75	188	87	133.1	
1:00	482	481	482	220.1	220.1	221.3	60	75	188	87	146.9	
1:15	479.3	479.1	478.3	230	228.4	228.3	60	72	190	88	152.9	
Hour reading at end												

Remarks:

- NOTES:
- Formula to calculate resistive load : $kW \times 1000 / Volts = \text{single ph amps}$
 $kW \times 1000 / Volts / 1.73 = 3 \text{ ph amps}$
 - Generator was run under load for warm - up approx. 5 - 10 min.
 - Record all readings every 10 minutes

Technician
 Customer/Witness