



Load Bank Test Report

Customer WPC

Date:

1. Autostart Function LOP HWT OS Hz
 2. Battery Voltage (running) _____

Job # / Location HQ
 Brand Cummins
 Model QST30
 Serial 37250907
 Engine QST30-G5
 KW 942
 Voltage 480V

Hour reading at start	368.6									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Temp. F	Temp. F	kW	Hours	
3:40 PM	480	480	481	227	230	233	60	4.79 Bar	75.9 C	25 C	190	368.6	
	480	480	479	227	230	230	60	4.76 Bar	76.2 C	25 C	188	368.7	
3:50 PM	480	479	480	457	460	460	60	4.70 Bar	76.5 C	25 C	380	368.8	
	481	482	481	457	459	458	60	4.64 Bar	77.1 C	25 C	377	368.9	
4:00 PM	481	481	480	700	701	703	60	4.59 Bar	77.6 C	25 C	584	369	
	480	482	481	700	700	701	60	4.52 Bar	78.2 C	25 C	579	369.1	
4:10 PM	480	480	481	933	931	933	60	4.48 Bar	79.8 C	25 C	772	369.8	
4:20 PM	481	481	482	933	933	936	60	4.37 Bar	82.9 C	25 C	776	370	
4:30 PM	480	479	481	933	933	934	60	4.33 Bar	83.7 C	25 C	774	370.2	
4:40 PM	481	481	482	936	934	939	60	4.31 Bar	83.7 C	25 C	779	370.3	
4:50 PM	480	479	480	931	930	934	60	4.32 Bar	83.7 C	25 C	772	370.5	
5:00 PM	481	481	482	933	933	936	60	4.34 Bar	83.7 C	25 C	776	370.6	
5:10 PM	482	482	481	934	933	936	60	4.33 Bar	83.5 C	25 C	777	370.7	
Hour reading at end	370.7												

Remarks: Started test at 25% load, increased to 50% load at 3:50 PM, increased load to 75% at 4 PM, increased load to 100% at 4:10 PM. Unit performed as expected.

- NOTES:
- Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
 kW x 1000 / Volts / 1.73 = 3 ph amps
 - Generator was run under load for warm - up approx. 5 - 10 min.
 - Record all readings every 10 minutes

Technician PR
 Customer/Witness RF