



Load Bank Test Report

Job # / Location _____ SHOP _____
 Brand **CUMMINS** _____
 Model **C300D6R-1328745** _____
 Serial **E130510437** _____
 Engine _____
 KW **300KW** _____
 Voltage **277/480** _____

Customer WPS _____

Date: **11/8/2023**

- 1. Autostart Function _____ LOP _____ HWT _____ OS _____ Hz
- 2. Battery Voltage (running) _____

Hour reading at start	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Coolant Temp. F	Ambient Temp. F	kW	Run Hours
9:30	482	482.7	482	95.2	95.4	95.4	60	43	186		79.3	
9:45	482.3	483	482.4	184.1	184.5	184.7	60	37	186		153.5	
10:00	482.3	483	482.4	281.5	282.4	282.8	60	37	186		235.2	
10:15	482.3	483	482.2	282.1	282.6	282.6	60	36	186		235.3	
10:30	482.1	483	482.2	340.8	341.9	342.6	60	36	186		284.8	
Hour reading at end												

Remarks:

- NOTES:
- 1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
 kW x 1000 / Volts / 1.73 = 3 ph amps
 - 2. Generator was run under load for warm - up approx. 5 - 10 min.
 - 3. Record all readings every 10 minutes

Technician _____
 Customer/Witness _____