



Load Bank Test Report

Job # / Location SHOP
Brand SDMO
Model T16UCM
Serial 5210
Engine 5MVXL01
KW 15KW
Voltage 120/240V

Customer WPC

Date: 4/6/2023

- 1. Autostart Function LOP HWT OS Hz
2. Battery Voltage (running)

Table with columns: Hour reading at start, Time, Volts (A-B), Volts (B - C), Volts (C - A), Amps (Phase A), Amps (Phase B), Amps (Phase C), HZ, Oil PSI, Coolant Temp. F, Ambient Temp. F, kW, Run Hours. Contains data for 12:15, 12:20, 12:30, and 12:40.

Remarks:

- NOTES: 1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
2. Generator was run under load for warm - up approx. 5 - 10 min.
3. Record all readings every 10 minutes

Technician
Customer/Witness