



Load Bank Test Report

Job # / Location SHOP
Brand CUMMINS
Model A042R104
Serial A130440264
Engine CUMMINS
KW 200KW
Voltage 480V

Customer WPS

Date: 03/22/2024

- 1. Autostart Function LOP HWT OS Hz
2. Battery Voltage (running)

Table with 13 columns: Hour reading at start, Time, Volts (A-B), Volts (B - C), Volts (C - A), Amps (Phase A), Amps (Phase B), Amps (Phase C), HZ, Oil PSI, Coolant Temp. F, Ambient Temp. F, kW, Run Hours. Contains data for 11:00, 11:30, 11:45, and 12:00.

Remarks:

- NOTES: 1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
2. Generator was run under load for warm - up approx. 5 - 10 min.
3. Record all readings every 10 minutes

Technician
Customer/Witness