



Load Bank Test Report

Customer WPS

Date: 4/25/2024

1. Autostart Function LOP HWT OS Hz
 2. Battery Voltage (running) _____

Job # / Location SHOP
 Brand olympian
 Model 9150L92
 Serial GXC00900
 Engine FORD 6.8L
 KW 150KW
 Voltage 277/480V

Hour reading at start										Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Temp. F	Temp. F	kW	Hours	
1:35	480	480	480	30	30	30	60	40	195	68	25		
1:50	480	480	480	30	30	30	60	40	200	68	25		
2:05	480	480	480	60	60	60	60	40	200	69	50		
2:20	480	480	480	80	80	80	60	38	202	69	67		
2:35	480	480	480	80	80	80	60	38	202	69	67		
Hour reading at end													

Remarks:

- NOTES:
- Formula to calculate resistive load : $kW \times 1000 / Volts = \text{single ph amps}$
 $kW \times 1000 / Volts / 1.73 = 3 \text{ ph amps}$
 - Generator was run under load for warm - up approx. 5 - 10 min.
 - Record all readings every 10 minutes

Technician _____
 Customer/Witness _____