



Load Bank Test Report

Job # / Location _____ shop _____
 Brand **spectrum** _____
 Model **100GS** _____
 Serial **673417** _____
 Engine _____ FORD _____
 KW **100KW** _____
 Voltage **480V** _____

Customer WPS

Date: **12/19/2023**

1. Autostart Function _____ LOP _____ HWT _____ OS _____ Hz
 2. Battery Voltage (running) _____

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	76	HZ	Oil PS	Temp. F	Temp. F	kW	Hours
10:00	482.7	484.9	483.4	30.4	30.6	31.2	60	70	135		25.9	
10:15	481.9	485.1	483.4	61.6	61.6	63	60	58	145		52.3	
10:30	481.4	486.3	483.4	74.3	74.1	76	60	56	145		63.1	
10:45	481.4	486.3	483.4	74.3	74.1	76	60	56	145		63.1	
11:00	481.4	486.3	483.4	74.3	74.1	76	60	56	145		63.1	
Hour reading at end												

Remarks:

- NOTES: 1. Formula to calculate resistive load : $kW \times 1000 / Volts = \text{single ph amps}$
 $kW \times 1000 / Volts / 1.73 = 3 \text{ ph amps}$
 2. Generator was run under load for warm - up approx. 5 - 10 min.
 3. Record all readings every 10 minutes

Technician _____
 Customer/Witness _____