



# Load Bank Test Report

Customer WPS

Date: 8/28/2024

Job # / Location SHOP  
 Brand WACKER  
 Model G50  
 Serial 20289939  
 Engine \_\_\_\_\_  
 KW 25KW  
 Voltage 240V

1. Autostart Function (LOP / HWT / OS / Hz): \_\_\_\_\_

2. Battery Voltage (running) \_\_\_\_\_

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PS	Temp. F	Temp. F	kW	Hours
7:45	240		240	31		31	60	60	181	73	7.4	
8:00	240		240	62		62.8	60	46	181	73	14.8	
8:15	240		240	62		62.8	60	46	181	73	14.8	
8:30	240		240	85.2		86.3	60	45	183	73	20.4	
8:45	240		240	96		98.4	60	43	185	75	23.6	
9:00	240		240	121		120	60	42	187	75	29.4	
Hour reading at end	4505.1											

Remarks: \_\_\_\_\_

- NOTES:
- Formula to calculate resistive load : kW x 1000 / Volts = single ph amps  
 kW x 1000 / Volts / 1.73 = 3 ph amps
  - Generator was run under load for warm - up approx. 5 - 10 min.
  - Record all readings every 10 minutes

Technician \_\_\_\_\_

Customer/Witne: \_\_\_\_\_