

Load Bank Test Report

WPS

8/8/2024 Date:

1. Autostart Function (LOP / HWT / OS / Hz):

Т

2. Battery Voltage (running)

Job # / Location SHOP Brand SHINDAIWA Model SSG3015 Serial **D16301000222** Engine ISUZU ĸŴ 12KW 240V Voltage

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Temp. F	Temp. F	kW	Hours
11:30	241			23	23		60		150	75	5	
11:45	240			39	39		60		167	75	9	
12:00	240			39	39		60		180	75	9	
Hour reading at end												

Remarks:

NOTES:

1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps kW x 1000 / Volts / 1.73 = 3 ph amps 2. Generator was run under load for warm - up approx. 5 - 10 min. 3. Record all readings every 10 minutes

Technician

Customer/Witness