WOODSTOCK POWER COMPANY

Load Bank Test Report

Job # / Location SHOP
Brand **KOHLER**
Model
Serial **762766**
Engine JOHN DEERE
KW 175KW
Voltage 120/240V

Customer WPS

Date: 9/24/2024

1. Autostart Function (LOP / HWT / OS / Hz): _____
2. Battery Voltage (running) _____

Hour reading at start									Coolant	Ambient		Run
Time	**Volts (A-B)**	**Volts (B - C)**	**Volts (C - A)**	**Amps (Phase A)**	**Amps (Phase B)**	**Amps (Phase C)**	**HZ**	**Oil PSI**	**Temp. F**	**Temp. F**	**kW**	**Hours**
9:00	209.9	210.2	209.9	119.9	112.3	112.5	60	45	136	66	40.7	
9:15	209.9	210.1	209.8	226.3	226.6	226.4	60	42	180	66	82.2	
9:30	209.5	209.7	209.2	303.6	304.3	304.1	60	40	180	66	110.1	
9:45	209	209.1	208.5	428.4	430	429.4	60	40	176	66	155	
Hour reading at end												

Remarks:

_____

NOTES:

1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
   kW x 1000 / Volts / 1.73 = 3 ph amps
2. Generator was run under load for warm - up approx. 5 - 10 min.
3. Record all readings every 10 minutes

Technician _____

Customer/Witness _____