



Load Bank Test Report

Job # / Location _____ Shop _____
 Brand Kohler _____
 Model 300REOZD _____
 Serial 751179 _____
 Engine Detroit Diesel _____
 KW 300 _____
 Voltage 208 3ph _____

Customer _____

Date: 11/13/24

- 1. Autostart Function _____ LOP _____ HWT _____ OS _____ Hz
- 2. Battery Voltage (running) _____ 27.8

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	HZ	Oil PSI	Temp. F	Temp. F	kW	Hours
8:45	208.8	208.7	208.7	212.2	212.2	212.7	60	54	174	40		
9:00	207.2	207.8	207.1	416.7	418.2	418.8	60	50	188	40		
9:15	207.2	207.8	207.1	416.7	418.3	418.8	60	50	188	42		
9:30	206.4	207.3	206.3	618.9	622.9	623.1	60	50	188	43		
9:45	205.9	207	205.7	740.9	746.2	745.9	60	49	188	44		
10:00	205.8	206.9	205.6	780.7	781.6	780.4	60	48	189	45		
Hour reading at end	1685.4											

Remarks:

- NOTES:
- 1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps kW x 1000 / Volts / 1.73 = 3 ph amps
 - 2. Generator was run under load for warm - up approx. 5 - 10 min.
 - 3. Record all readings every 10 minutes

Technician _____
 Customer/Witness _____