Load Bank Test Report

Job # / Location	SHOP
Brand	Kohler
Model	300REOZJ
Serial	2343216
Engine	JOH DEERE
KW	300KW
Voltage	480V

Customer: _____

Date: 5/19/2025

1. Autostart Function _____LOP _____HWT _____OS _____Hz
2. Battery Voltage (ru 24V

Hour reading at start									Coolant	Ambient		Run
Time	**Volts (A-B)**	**Volts (B - C)**	**Volts (C - A)**	**Amps (Phase A)**	**Amps (Phase B)**	**Amps (Phase C)**	**HZ**	**Oil PSI**	**Temp. F**	**Temp. F**	**kW**	**Hours**
11:35	478.4	478.9	478.4	106.7	106.9	106.9	60	46	172	69	89	498.4
11:50	477.4	478.8	478.1	157.7	157.8	157.8	60	42	176	69	157	498.6
12:05	477.4	478.3	477.3	228.6	229.2	229.3	60	41	177	69	189	498.9
12:20	477.1	478	476.8	278.1	279.2	279.3	60	40	179	70	230	499.1
12:35	476.7	477.6	476.3	336.9	338.2	338.4	60	39	181	70	278	499.4
Hour reading at end												

Remarks:

NOTES:

1. Formula to calculate resistive load : kW x 1000 / Volts = single ph amps
   kW x 1000 / Volts / 1.73 = 3 ph amps
2. Generator was run under load for warm - up approx. 5 - 10 min.
3. Record all readings every 10 minutes

Technician _____

Customer/Witness _____