



Load Bank Test Report

Customer: _____

Date: 6/19/2025

1. Autostart Function _____ LOP _____ HWT _____ OS _____ Hz
2. Battery Voltage (ru 24V)

Job # / Location	SHOP
Brand	Katolight
Model	N255FRX4
Serial	125905-0706
Engine	Detroit 60G
KW	255kw
Voltage	480

Hour reading at start									Coolant	Ambient		Run
Time	Volts (A-B)	Volts (B - C)	Volts (C - A)	Amps (Phase A)	Amps (Phase B)	Amps (Phase C)	107 HZ	Oil PSI	Temp. F	Temp. F	kW	Hours
10:20	479	479	479	94	94	94	60	59	177	85	78	478
10:35	478	478	478	158	158	158	60	54	179	85	130	479
10:50	477	478	478	197	197	197	60	59	180	86	162	479
11:05	477	482	477	252	253	253	60	59	181	88	208	479
Hour reading at end												

Remarks:

NOTES:

- Formula to calculate resistive load : $kW \times 1000 / Volts = \text{single ph amps}$
 $kW \times 1000 / Volts / 1.73 = 3 \text{ ph amps}$
- Generator was run under load for warm - up approx. 5 - 10 min.
- Record all readings every 10 minutes

Technician _____
Customer/Witness _____